

臺北榮民總醫院藥學部

臨床試驗藥局一般藥品冷藏/冷凍/室溫溫度管制表 108年07月

	四號冰箱		五號冰箱		室溫2	
序號	1611-0062		1715-0118		1715-0116	
備用	1611-0052		1715-0119		1715-0117	
範圍	2~8°C		2~8°C		15~25°C	
日期	Min	Max	Min	Max	Min	Max
2019/7/1	5.1	5.6	4.9	5.3	20.6	21.3
2019/7/2	5.1	5.6	4.9	5.3	21.2	21.6
2019/7/3	5.1	5.6	4.9	5.9	21.1	21.6
2019/7/4	5.1	5.6	4.7	5.8	21.2	21.7
2019/7/5	5.1	5.6	4.8	5.2	21.4	21.9
2019/7/6	5.1	5.4	4.8	5.1	21.1	21.7
2019/7/7	5.1	5.5	4.8	5.1	20.6	21.1
2019/7/8	5.1	5.6	4.7	5.2	20.4	21.3
2019/7/9	5	5.6	4.7	5.8	20.8	21.4
2019/7/10	4.9	5.6	4.6	5.1	21.1	21.6
2019/7/11	5.1	5.8	4.6	5.1	21.2	21.8
2019/7/12	5.3	5.7	4.6	5.1	21.3	21.9
2019/7/13	5.2	5.7	4.6	4.9	21.2	21.7
2019/7/14	5.2	5.5	4.6	4.9	20.8	21.2
2019/7/15	5.2	5.7	4.6	5.1	20.6	21.4
2019/7/16	4.9	6.2	4.6	5.6	20.9	21.7
2019/7/17	4.9	5.8	4.5	5.4	21.3	21.7
2019/7/18	4.9	6	4.4	5.2	21.4	22.1
2019/7/19	4.9	5.5	4.7	5.1	21.5	22.3
2019/7/20	4.9	5.5	4.7	5.1	21.5	22
2019/7/21	4.9	5.4	4.7	5.1	21.2	21.5
2019/7/22	4.9	5.5	4.7	5.1	20.9	21.3
2019/7/23	4.8	5.5	4.7	5.2	20.8	21.3
2019/7/24	4.7	5.4	4.4	5.4	20.9	21.3
2019/7/25	4.7	5.4	4.5	5.2	20.9	21.7
2019/7/26	4.8	5.4	4.5	5	21.4	21.9
2019/7/27	4.7	5.5	4.6	4.9	21.3	21.9
2019/7/28	4.7	5.3	4.6	4.9	20.6	21.2
2019/7/29	4.7	5.7	4.5	5.1	20.5	21.1
2019/7/30	4.7	5.5	4.5	5.2	20.7	21.6
2019/7/31	4.7	5.4	4.7	5.1	20.9	21.8

註1: 溫度記錄器型號: ESCORT/ Model No.: EI-IN-D-32-L

註2: 溫度記錄器更換電池或送校正期間取備用紀錄器之資料

承辦藥師: 藥學部 邱保祥 108
師(三)級藥師 286 藥學部 溫雅如 108
師(三)級藥師 281