

# 臺北榮民總醫院藥學部

## 臨床試驗藥局一般藥品冷藏/冷凍/室溫溫度管制表 114年 01月

	零號冰箱		四號冰箱		五號冰箱		八號冰箱		九號冰箱		室溫2	
序號	2052-0128		1611-0062		1715-0118		2123-0024		2123-0028		1715-0116	
備用	2052-0129		1611-0052		1715-0119		2123-0025		2123-0029		1715-0117	
範圍	2~8°C		2~8°C		2~8°C		2~8°C		2~8°C		15~25°C	
日期	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
2025/1/1	4.5	4.7	4	4.7	4.5	4.9	4.5	4.9	3.8	4.8	19.4	21.6
2025/1/2	4.6	5.3	4.2	4.8	4.5	6.3	4.6	5.2	3.7	5.3	20.1	20.3
2025/1/3	4.5	4.7	4.1	4.8	4.5	5.3	4.6	5	3.7	4.8	19.7	20.1
2025/1/4	4.5	4.7	4	4.7	4.5	4.8	4.7	5	3.7	4.8	19.5	19.7
2025/1/5	4.6	4.7	4	4.7	4.5	4.8	4.7	5	3.7	4.8	19.4	19.5
2025/1/6	4.6	4.8	4	4.7	4.5	4.9	4.7	5.1	3.6	4.8	18.9	19.4
2025/1/7	4.6	4.8	4.1	4.7	4.5	4.9	4.7	5.1	3.9	4.9	18.6	18.9
2025/1/8	4.6	4.8	3.9	4.7	4.4	4.9	4.7	5	3.8	4.8	18.4	19
2025/1/9	4.2	4.8	4.1	4.8	4.4	4.8	4.7	5.7	3.6	4.7	18.7	19.3
2025/1/10	4.2	4.4	4.1	4.7	4.3	4.9	5.3	5.6	3.3	4.7	18.8	19.1
2025/1/11	4.2	4.4	4.1	4.7	4.3	4.8	5.3	5.6	3.3	4.5	18.7	19.1
2025/1/12	4.2	4.4	4.1	4.7	4.4	4.7	5.3	5.6	3.3	4.5	18.9	19.1
2025/1/13	4.2	4.4	4.1	4.7	4.3	5.1	5.3	5.6	3.3	4.6	18.8	19.4
2025/1/14	4.1	4.4	4.1	4.7	4.3	4.9	5.3	5.6	3.3	4.6	19.3	19.9
2025/1/15	4.1	4.4	4.1	4.7	4.3	4.7	5.4	5.7	3.2	4.7	19.8	20.1
2025/1/16	4.1	4.4	4.1	4.7	4.3	4.7	5.3	5.6	3.2	4.6	19.6	19.9
2025/1/17	4.1	4.4	4.1	4.7	4.3	4.8	5.3	5.6	3.1	4.5	19.4	19.7
2025/1/18	4.1	4.3	4.1	4.6	4.4	4.7	5.3	5.6	3.2	4.5	19.4	19.6
2025/1/19	4.1	4.3	4.1	4.6	4.3	4.7	5.3	5.5	3.2	4.5	19.6	19.7
2025/1/20	4.1	4.7	4.1	4.7	4.3	4.7	4.9	5.6	3.2	4.8	19.6	19.9
2025/1/21	4.4	4.7	4.1	5.2	3.3	4.8	4.9	5.2	3.1	4.8	19.7	20.2
2025/1/22	4.4	4.7	4.1	4.7	2.6	4.3	4.7	5.2	3.2	4.6	20.1	20.6
2025/1/23	4.4	4.8	4.1	4.7	2.6	4.3	4.7	5.2	2.9	4.9	20.4	20.7
2025/1/24	4.5	4.8	4.1	4.7	3.1	4.4	4.7	5.2	2.9	4.1	20.1	20.6
2025/1/25	4.5	4.7	4.2	4.7	3.2	4.1	4.7	5.2	3.2	4.1	19.3	20.1
2025/1/26	4.5	4.7	4.2	4.7	3.3	4.1	4.7	5.2	3.2	4.2	19	19.3
2025/1/27	4.5	4.7	4.2	4.7	3.3	4.1	4.7	5.2	3.3	4.2	18.3	19
2025/1/28	4.5	4.7	4.2	4.7	3.3	4.1	4.7	5.2	3.3	4.2	18	18.3
2025/1/29	4.5	4.7	4.2	4.7	3.3	4	4.7	5.1	3.3	4.1	18.2	18.6
2025/1/30	4.5	4.7	4.2	4.7	3.3	4	4.7	5.1	3.2	4.1	18.6	18.9
2025/1/31	4.6	4.8	4.2	4.7	3.2	4	4.7	5.2	3.2	4.1	18.9	19.3

註1: 溫度記錄器型號: ESCORT/ Model No.: EI-IN-D-32-L

註2: 溫度記錄器更換電池或送校正期間取備用紀錄器之資料

承辦藥師: 藥學部 葉馨 114 0203  
藥學部 邱保祥 114 0203

總藥師: 藥學部 廖志峰 師(二)級藥師 1600

業管主管: 藥學部 何沁沁 科主任 0205 1160